

No. 4/14-2015-CTE/2040
GOVERNMENT OF MANIPUR
OFFICE OF THE CONTROLLER OF TECHNICAL EDUCATION: MANIPUR

Imphal, the 4th January, 2016.

To, ✓
The Commissioner (Hr. & Tech. Edn.),
Government of Manipur.

Sub :- Report on the result of the Earthquake on 4th January, 2016 at around 4:35 a.m.

Sir,

I am submitting herewith the preliminary report on the damages caused by the recent earthquake at around 4:35 a.m. of 4th January, 2016 for favour of further necessary action by performing further assessment and rehabilitation works.

The major damages that can be observed from visual observation are as follows:

(A) Main Building (Class room) Block:-

- (i) Clock tower in the front completely crushed and sat on top of the building,
- (ii) Most of the walls cracked severely,
- (iii) Almost all the front columns crushed
- (iv) Staircase of the building was also damaged.

(B) Administrative Building:-

- (i) Beam/Slab sagged in,
- (ii) Wall cracked and (iii) a portion of the parapet collapsed

(C) Multipurpose Hall:-

- (i) Most of the ceiling crumbles down and cracks are also found in the walls,
- (ii) Staircase of the building was also damaged,
- (iii) The stage area was also severely damaged,

(D) Pharmacy Building:-

- (i) All round cracks in the walls

(E) Library Building:-

- (i) Cracks are found in the column and walls as the central column sagged.

(F) Hostels (Both Boys' and Girls'):- Extensive cracks in walls, staircases and Mess halls.

It is to mention that as a precaution to avoid loss of life as the above buildings are found to be unsafe for conducting classes where new session for Diploma Engineering was scheduled to begin from today, the 4th January, 2016, classes has been suspended until the building is certified to be safe by a competent authority.

Enclosed:- Photographs showing the damages.

IMPORTANT & URGENT

*P. put up on file
urgently.*

*DSTHE
hari*

[Signature]
4/1/16
9/1/16

Yours faithfully,

[Signature]
(Kh. Rajchandra Singh)


Controller of Technical Education, Manipur.

Imphal, the 4th January, 2016.

No. 01/01/2015-GPI(Acad)/116

NOTICE FOR SUSPENSION OF CLASSES

This is for information to all the concerned persons, that due to severe damage of the Main Academic Block, Administrative Building, Multipurpose Hall, Library building, etc, in the recent earthquake on the 4th January, 2016 at around 4:35 a.m. normal classes of Diploma Engineering Terms-II, IV and VI which was scheduled to begin from the 4th January, 2016 remains suspended until further order.




(Kh. Rajchandra Singh)

Principal,

Government Polytechnic, Imphal.

Copy to:-

- (i) The Commissioner (Hr. & Tech. Edn.), Government of Manipur- for information.
- (ii) The Incharge (Academics), Govt. Polytechnic, Imphal – for information and necy. action.
- (iii) All concerned persons, Govt. Polytechnic, Imphal – for information and necy. action.
- (iv) Notice board,
- (v) Guard file.



ACADEMIC BUILDING





ACADEMIC BUILDING

ACADEMIC BUILDING

ACADEMIC BUILDING

ACADEMIC BUILDING

Academic building

ADMINISTRATIVE BUILDING



PHARMACY BUILDING



PHARMACY BUILDING



HOSTEL BUILDING